

Case Study: Requirement for Flame Retardant, Personnel Protective Equipment Data Management Networks (South)



The above image highlights the serious consequences of contact with a high voltage cable; the operative concerned was not wearing flame retardant coveralls. The task for the operative was to excavate for the installation of lamp posts for a local authority, utility records on site were of a consultancy multi utility nature at not at an interpretable scale. The operative came into contact with the high voltage cable in the footpath with a compressor gun at a depth of 600mm, unfortunately on this occasion the operative was hospitalised with serious burns to his legs and head. Prior to undertaking excavations it is essential that the correct personal protective equipment required to undertake the task is supplied and utilised.

Personal Protective Equipment (PPE) Is The Last Line In Defence. Prior To Carrying Out Excavations, Plan the Project

All Cable Record enquiries should be addressed to:

SP Energy Networks (North)

Data Management (Correspondence) 55 Fullerton Drive Cambuslang Glasgow G32 8FD

t: 0141 567 4155 or 0141 567 4455

e: Requestforplansscotland @scottishpower.com

(Correspondence) North Cheshire Trading Estate Prenton Way Prenton Birkenhead CH43 3ET

t: 0151 609 2373

e: Requestforplansmanweb @manweb.co.uk

All Cable Deviation Requests /Service Alterations enquiries should be addressed to:

SP Energy Networks (North)

Customer Connections 55 Fullerton Drive Cambuslang Glasgow G32 8FA

t: 0141 614 9997

SP Energy Networks (South)

Customer Connections PO Box 290 Lister Drive Liverpool L13 7HJ

t: 0151 221 2110

Emergency contact

In an emergency, or if there is any damage to SP Energy Networks cables or plant, call the appropriate number:



0845 272 2424