

## 1. SCOPE

This document details SP Distribution plc's (SPD) and SP Manweb plc's (SPM) technical requirements for the handling and installation of power cables up to and including 33kV onto the SPEN network.


## 2. ISSUE RECORD

This is a [Reference](#) document. The current version is held on the EN Document Library.

**It is your responsibility to ensure you work to the current version.**

Issue Date	Issue No.	Author	Amendment Details
July 2010	7	Paul Cunningham	Updated to include Aluminium 33kV cables.
May 2011	8	Paul Cunningham	Joint bay dimensions updated following Engineering and Ergonomic assessment.
Jan 2015	9	Paul Cunningham	Updated to add requirements for provision of Condition Monitoring equipment and to consider route conditions during design phase.
09/03/2020	10	Adam Merrilees	Section 12.3 – Marker Tape and Protection Tiles: Reference to installation of ENA TS 12-23 Class 1 & 2 protection tiles. Section 21.9 – Ducts: Minimum diameter specified as an inside diameter. Section 22 – sealing procedure from referenced archived express, EXP-11-068 added.

## 3. ISSUE AUTHORITY

Author	Owner	Issue Authority
Adam Merrilees Senior Engineer	Frank Berry Circuits Manager, Engineering Design & Standards	Fraser Ainslie Head of Engineering Design & Standards    Date: 13/03/2020

## 4. REVIEW

This is a [Reference](#) document which has a 5 year retention period after which a reminder will be issued to review and extend retention or archive.

## 5. DISTRIBUTION

This document is part of the Construction Virtual Manual maintained by Document Control and does not have a maintained distribution list. It is published on the SP Energy Networks website.

**6. CONTENTS**

<b>1. SCOPE.....</b>	<b>1</b>
<b>2. ISSUE RECORD.....</b>	<b>1</b>
<b>3. ISSUE AUTHORITY .....</b>	<b>1</b>
<b>4. REVIEW .....</b>	<b>1</b>
<b>5. DISTRIBUTION.....</b>	<b>1</b>
<b>6. CONTENTS .....</b>	<b>2</b>
<b>7. REFERENCE AND RELATED DOCUMENTS.....</b>	<b>4</b>
<b>7.1 Legislation .....</b>	<b>4</b>
<b>7.2 National Specifications and Guidance.....</b>	<b>4</b>
<b>7.3 SPEN Documents.....</b>	<b>4</b>
<b>8. DEFINITIONS .....</b>	<b>4</b>
<b>9. GENERAL REQUIREMENTS .....</b>	<b>5</b>
<b>10. INTRODUCTION.....</b>	<b>5</b>
<b>11. AVOIDING DANGER.....</b>	<b>5</b>
<b>12. MATERIALS .....</b>	<b>5</b>
<b>12.1 Cable Bedding and Surround Materials.....</b>	<b>5</b>
<b>12.2 Cable Sealing Caps.....</b>	<b>5</b>
<b>12.3 Marker Tape, Protection Tape and Protection Tiles .....</b>	<b>5</b>
<b>12.4 Ducts.....</b>	<b>6</b>
<b>13. ENGINEERING DESIGN .....</b>	<b>6</b>
<b>13.1 Route Selection .....</b>	<b>6</b>
<b>13.2 Use of Ducts .....</b>	<b>6</b>
<b>13.3 Provision of Condition Monitoring Equipment .....</b>	<b>6</b>
<b>14. PRECAUTIONS IN COLD WEATHER.....</b>	<b>6</b>
<b>15. SETTING UP DRUM PRIOR TO CABLE PULLING.....</b>	<b>6</b>
<b>15.1 General safety principles.....</b>	<b>6</b>
<b>15.2 Positioning the cable drum .....</b>	<b>7</b>
<b>15.3 Using drum jacks .....</b>	<b>7</b>
<b>15.4 Removing battens &amp; lagging.....</b>	<b>7</b>
<b>15.5 Checking cable details and sealing cap integrity .....</b>	<b>7</b>
<b>16. PREPARATION OF TRENCH AND DUCTS.....</b>	<b>7</b>
<b>17. CABLE PULLING .....</b>	<b>8</b>
<b>17.1 Installation parameters .....</b>	<b>8</b>
<b>17.2 Drum control during pulling.....</b>	<b>8</b>
<b>17.3 Winches.....</b>	<b>8</b>
<b>17.4 Cable guides and rollers.....</b>	<b>8</b>
<b>17.4.1 Straight horizontal run.....</b>	<b>8</b>

17.4.2	Bends in route.....	8
17.4.3	Roller adjustment and protection of other services .....	8
<b>17.5</b>	<b>Single core cables .....</b>	<b>8</b>
17.5.1	Configuration.....	8
17.5.2	Ducted single core installations .....	9
<b>17.6</b>	<b>Completion.....</b>	<b>9</b>
<b>17.7</b>	<b>Cable sealing .....</b>	<b>9</b>
17.7.1	Cables with lead sheath.....	9
17.7.2	Cables without lead sheath.....	9
<b>18.</b>	<b>ALTERNATIVE INSTALLATION TECHNOLOGIES .....</b>	<b>9</b>
18.1	Ducted Installations .....	10
18.2	Trenchless Installations .....	10
18.3	Installation by Plough or Trenching Machine .....	10
<b>19.</b>	<b>BLINDING OF CABLES AND JOINTS .....</b>	<b>10</b>
<b>20.</b>	<b>CABLE TESTING AND COMMISSIONING .....</b>	<b>10</b>
<b>21.</b>	<b>APPENDIX 1 – REQUIRED INSTALLATION PARAMETERS.....</b>	<b>11</b>
21.1	General .....	11
21.2	Bedding Materials .....	11
21.2.1	Definitions .....	11
21.2.2	LV Cables .....	11
21.2.3	11kV Cables.....	11
21.2.4	33kV Cables.....	11
21.3	Maximum Pulling Tensions.....	12
21.4	Minimum Bending Radii .....	13
21.5	Depth of Cover.....	14
21.6	Position of Warning Tapes, Protection Tapes and Protection Tiles.....	14
21.7	Multiple Cable Spacing .....	15
21.8	Joint Bay Dimensions.....	15
21.9	Ducts.....	16
21.10	As Laid Records .....	16
<b>22.</b>	<b>APPENDIX 2 – SEALING WIRE ARMOURED PLASTIC SHEATHED PILOT AND TELECOMS CABLES.....</b>	<b>17</b>
22.1	Background .....	17
22.2	Procedure.....	17

## **7. REFERENCE AND RELATED DOCUMENTS**

### **7.1 Legislation**

Electricity Safety, Quality and Continuity (ESQC) Regulations

### **7.2 National Specifications and Guidance**

ENA TS 09-02 Specification for the supply, delivery & installation of power cables with operating voltages in the range 11kV to 400kV and associated auxiliary cables

ENA TS 12-23 Polyethylene Warning Tape, Polyethylene Protection Tape and Polyethylene Protection Tiles for Buried Electricity Supply Cable

ENA TS 97-1 Special backfill materials for buried electric cables

HSG47 Avoiding danger from underground services

HSG185 Health and Safety in Excavations

### **7.3 SPEN Documents**

BUPR-22-015 Recording of Electrical Assets by Contractors

CAB-03-028 Specification for Ducting for Power Cables

CAB-06-001 Approved Equipment Register – Cables & Cable Accessories

SUB-02-613 Electrical Insulation Testing of HV Equipment up to 33kV

Health, Safety and Environmental Handbook (excavations, cabling and jointing sections).

## **8. DEFINITIONS**

SPEN	SP Energy Networks, the brand name for the division of the ScottishPower group of companies that encompasses SP Transmission plc, SP Distribution plc, SP Manweb plc, SP Power Systems Ltd and ScottishPower Energy Networks Holdings Ltd.
SP Transmission plc (SPT)	The Transmission Licence Holder for the transmission service area formerly known as ScottishPower.
SP Distribution plc (SPD)	The Distribution Licence Holder for the distribution service area formerly known as ScottishPower.
SP Manweb plc (SPM)	The Distribution Licence Holder for the distribution service area formerly known as Manweb.
Approved	Equipment approved in accordance with SPEN's Equipment Approvals Procedure and which is considered suitable for use and/or installation on SPEN's networks. Approval shall be given in writing by the Specifying Engineer.
Specifying Engineer	Person nominated by SP Energy Networks having responsibility and authority for all technical matters relating to execution of the works.

## **9. GENERAL REQUIREMENTS**

SPD and SPM reserve the right to change the data contained in this document without notification. Although specific network extensions may be designed and constructed by third parties, SPD and SPM retain the responsibility for the design and construction standards of the distribution system. Since the guidance cannot cover every eventuality, SPD and SPM reserve the right to apply other criteria where necessary and appropriate.

The installer is responsible for ensuring that they have all the relevant information required to undertake construction. Only installers who have the appropriate skills, training and experience shall use the data and guidance contained in this document. This document provides guidance, however, it is the installer's responsibility to ensure that safe systems of work are employed on site.

## **10. INTRODUCTION**

The document defines the limits prescribed by SPEN for each of the following parameters:

- Maximum pulling tensions.
- Minimum static and dynamic bending radii.
- Depth of cover.
- Positioning of marker tapes and protection tiles.
- Multiple cable spacing.

The following sections detail the procedures which shall be followed when handling and installing power cables. These procedures are based on safe working practices and are designed to minimise the risk of damage to the cable being installed.

Attention is drawn to the requirements of the New Roads and Street Works Act (NRSWA) which must be complied with where appropriate.

## **11. AVOIDING DANGER**

Attention is drawn to the requirements and recommendations contained in Health and Safety Executive guidance notes HSG47 "Avoiding Danger from Underground Services" and HSG185 "Health and Safety in Excavations". Further guidance is provided to SPEN staff in the SPEN Health, Safety and Environmental Handbook.

## **12. MATERIALS**

All cables and associated materials for installation on the SPEN network shall be new and classified as Approved on the approved equipment register, CAB-06-001.

### **12.1 Cable Bedding and Surround Materials**

Cables shall be bedded in and surrounded by appropriate materials as defined in Section 21.2.

### **12.2 Cable Sealing Caps**

Only Approved cable sealing end caps shall be used.

### **12.3 Marker Tape, Protection Tape and Protection Tiles**

All warning tape, protection tape and protection tiles installed on the SPEN network shall be Approved.

Warning tapes shall be installed as specified above all LV cables.

Protection tapes shall be installed as specified above all 11kV cables.

ENA TS 12-23 Class 2 protection tiles shall be installed to protect cables operating at voltages between 33kV and 132kV.

ENA TS 12-23 Class 1 protection tiles shall be installed to protect cables operating at voltages of 132kV and above.

Protection tiles supplied with a pin interlocking system shall be installed interlocked with the Approved manufacturer's pins.

#### **12.4 Ducts**

All ducts and ducting accessories for installation on the SPEN network shall be new and classified as Approved on the approved equipment register, CAB-06-001.

### **13. ENGINEERING DESIGN**

#### **13.1 Route Selection**

All cable installations shall be preceded by a route survey to establish and confirm that the conditions along the route are appropriate for reliable and maintenance free operation of the cable over its expected lifetime.

The route survey should consider, but not necessarily be limited to, the following:

- Ground conditions.
- Access for repairs and maintenance.
- Location of other services.

Consideration needs to be given at the design stage to how the cable system will be maintained and to ensure access provisions are made so that required repairs and maintenance can be carried out as required over the lifetime of the cable.

#### **13.2 Use of Ducts**

Cable runs shall not be installed in ducts unless the design has been agreed by the Specifying Engineer and any de-rating taken into account.

#### **13.3 Provision of Condition Monitoring Equipment**

All new 33kV circuits utilising single core cables with a length of 5km or more shall be provided with condition monitoring equipment which shall include as a minimum:

- Phase current measurement and recording.
- Phase voltage measurement and recording.
- Sheath currents measurement and recording.
- Travelling wave fault location equipment.

### **14. PRECAUTIONS IN COLD WEATHER**

To avoid damage to the oversheath and/or insulation of cables in cold weather, PVC sheathed cables (Waveform, service, multicore and multipair cables) shall be maintained above 0°C and Polyethylene sheathed cables (11kV and 33kV xlpe insulated cables) shall be maintained above -5°C for a minimum of 24 hours before laying or otherwise bending.

### **15. SETTING UP DRUM PRIOR TO CABLE PULLING**

#### **15.1 General safety principles**

- Carry out, record and maintain a site specific risk assessment.
- Always wear appropriate PPE.

- Always push drums in the direction of travel.
- Never pull drums with back to the direction of travel.
- Push squarely on the flanges and watch for any projecting nails in wooden drums.
- Always use Approved equipment for handling drums, never use improvised equipment.
- Never allow a drum to move in an uncontrolled manner.
- Never position or store a drum underneath an overhead line.

### 15.2 Positioning the cable drum

Always observe the correct direction of roll indicated by the “roll this way” arrow on the drum flange. Position the drum so that the pull from the drum to the trench is as straight as possible, in any case, the lead in angle of the cable to the trench shall not be greater than 30°. A lead in roller shall always be used to guide the cable into the trench.

When pulling a cable into a duct the drum shall be positioned above the duct so that the cable leaves the drum and enters the duct in a smooth curve. The drum shall be rotated by hand during the installation to minimise tension between the drum and the duct mouth.

Cable drums should be arranged such that the “A” end of one length is positioned for jointing on to the “Z” end of the next length.

### 15.3 Using drum jacks

Check that the jacks and spindle are adequate for the size and weight of the cable drum, the gross weight of the cable drum will be marked on one flange.

### 15.4 Removing battens & lagging

Battens or other drum protection should be removed carefully to ensure that any nails or tools do not damage the cable. Care should be taken when removing any metal strapping used to secure lagging, this strapping may be under considerable tension and can spring with some force when cut. Ensure that no nails are left protruding from the drum flanges as these may result in injury when moving or handling the drum. Ensure correct disposal of any excess materials.

### 15.5 Checking cable details and sealing cap integrity

The end of the cable should be freed and inspected to ensure that:

- The cable is of the correct size and type.
- The cable sealing cap is intact and undamaged.
- On a new drum the length marking on the oversheath agrees with the details marked on the cable drum.

## 16. PREPARATION OF TRENCH AND DUCTS

- The trench bottom shall be as level as possible and any change in gradient or level shall be made as gradually as possible.
- The trench bottom shall be free of stones and other sharp objects and the edges of the trench shall be cleared of any stones, tools or objects which may fall into the trench and damage the cable.
- Ducts shall be cleaned and proved prior to cable installation by pulling through a mandrel and cleaning pig of suitable diameters.
- Duct entries shall be fitted with split bell mouths to prevent damage to the cable and to the duct entry. The bell mouth shall be fitted so that the cable does not run on the split during installation to avoid the risk of damage to the cable oversheath.

- A shallow pit shall be dug at duct entry positions to ensure that stones etc. are not dragged into the duct.

## **17. CABLE PULLING**

### **17.1 Installation parameters**

Requirements for depth of cover, maximum pulling tensions, minimum bending radii, minimum cable spacings and position of marker tapes and protection tiles are detailed in Appendix 1.

### **17.2 Drum control during pulling**

At all times during cable installation, the drum's rotation shall be controlled and the stability of the drum and jacks monitored.

### **17.3 Winches**

Where a winch is used to pull in cables, the winch shall be fitted with a suitable dynamometer. The dynamometer shall be continuously monitored to ensure that the maximum pulling tension is not exceeded at any time. In all cases an appropriate swivel eye shall be fitted between the pulling bond and the pulling attachment on the cable.

### **17.4 Cable guides and rollers**

#### **17.4.1 Straight horizontal run**

The cable shall be supported on free running cable rollers which have no projections or sharp edges.

Rollers shall be placed in the trench to prevent the cable from dragging on the trench bottom or in mud. The roller spacing required to achieve this will depend on the cable type being installed and the pulling tension along the route.

A leading roller shall be used to support the cable over the entire drum width immediately before being fed into the trench.

#### **17.4.2 Bends in route**

Vertical corner rollers shall not be used as they may damage the cable by causing excessive side wall pressure. Skid plates of a radius greater than the cable's minimum dynamic bending radius shall be used on all bends.

#### **17.4.3 Roller adjustment and protection of other services**

Prior to commencement of pulling, initial tension should be taken up to take the slack out of the bond wire. The rollers along the route should be checked and adjusted to line up with the taut bond and a final check should be made to ensure that other services will not be rubbed or abraded by the cable during installation.

When final roller positions are confirmed and the cable is verified to be clear of all other services, the pull can be started.

### **17.5 Single core cables**

#### **17.5.1 Configuration**

Where single core cables are laid direct in the ground to form one three-phase circuit, they shall, unless otherwise instructed by the Specifying Engineer, be laid in touching trefoil. They shall be bound together using nylon cable ties at intervals of one metre. The nylon cable ties shall have a smooth internal surface and have a minimum loop tensile strength of 54kg.



### 17.5.2 Ducted single core installations

Where single core cables are to be installed in ducts to form a three-phase circuit, they shall, unless otherwise instructed by the Specifying Engineer, be installed with each core in an individual duct and with the ducts laid in touching trefoil. The duct groups shall be bound together using nylon cable ties at intervals of one metre. The nylon cable ties shall have a smooth internal surface and have a minimum loop tensile strength of 54kg.

It is acceptable to install three single core cables in a single duct for short lengths such as road crossings. In this case all 3 cores must be pulled in simultaneously.

## 17.6 Completion

When installation is complete, all cut cable ends must be sealed by capping in accordance with approved procedures. All unused cable must be capped before returning to stores.

The loose end of the cable remaining on the drum shall be rewound tightly onto the drum by means of a length of rope tied around the cable end and secured to the drum.

After securing the cable end lower the drum jacks keeping the drum level. Remove, clean and store the spindle and drum jacks.

## 17.7 Cable sealing

Irrespective of insulation type, all cut ends of cables, including cable left on the drum, shall be sealed immediately and not left exposed to the atmosphere. This applies whether the cables are cut at stores, in the yard or on site.

All end caps, including factory fitted end caps, shall be examined after laying and any cap found to be damaged shall be removed and the cable resealed immediately and the Specifying Engineer notified.

### 17.7.1 Cables with lead sheath

- For cables with lead sheaths the sealing cap shall be applied directly onto the lead sheath.
- Measure the diameter over the lead sheath and select the appropriate size of sealing cap.
- Expose the lead sheath for a distance equal to the length of the sealing cap plus 50mm from the cut cable end.
- Clean the exposed lead sheath using Approved cable degreasing solvent wipes.
- Install the sealing cap in accordance with the instructions provided with each cap.

### 17.7.2 Cables without lead sheath

- For cables without lead sheaths the sealing cap shall be applied directly onto the PVC or MDPE cable oversheath.
- Measure the diameter over the PVC/MDPE oversheath and select the appropriate size of sealing cap.
- Clean and abrade the cable oversheath.
- Install the sealing cap in accordance with the instructions provided with each cap.
- Pilot and Telecoms cables shall be "double-sealed" using mastic tapes and cold-applied caps as detailed in Appendix 2.

## 18. ALTERNATIVE INSTALLATION TECHNOLOGIES

The requirements specified in this document apply in general to all underground cable installations irrespective of the installation method used.

Installation shall be carried out by experienced teams with a thorough understanding of the risks specific to the installation methods being used.

The installation design, equipment and techniques shall be designed to:

- Minimise pulling forces on cables.
- Cause no damage to cable sheaths during handling and installation.
- For single core cables, be capable of reliably installing the cables in touching trefoil formation.
- For single core cables in ducts, be capable of reliably installing the ducts in touching trefoil formation.

The following gives some clarification and guidance.

### **18.1 Ducted Installations**

Ducted installations shall be installed to meet the same requirements for surround materials, depth of cover and warning tapes/tiles as applied for direct buried cables.

### **18.2 Trenchless Installations**

Cables shall not be installed directly by trenchless means. Trenchless installation shall be achieved by installation of a duct which the cable(s) can be subsequently pulled into. In this situation it is not possible to install warning tapes/tiles and the markings on the Approved ducts in conjunction with the presence of the specified surround material can usually be considered adequate to provide the warning required by the ESQC Regulations. In certain situations it may be necessary to install additional warning such as marker posts or signs depending on the route, location and depth of cover.

### **18.3 Installation by Plough or Trenching Machine**

Cables or ducts may be installed using ploughing or trenching techniques. The requirements for surround materials and depth of cover remain unchanged for this type of installation. Standard 11kV and 33kV warning tape/tiles are not suitable for installation by these methods and an Approved and appropriate alternative warning tape shall be used. In certain situations it may be necessary to install additional warning such as marker posts or signs depending on the route, location and depth of cover.

The capabilities of ploughing and trenching contractors must be fully assessed by SPEN prior to Approval to carry out installation work.

## **19. BLINDING OF CABLES AND JOINTS**

The following points are recognised as good practice and should be followed where reasonably practicable:

- Blinding shall be completed immediately following the installation of sections of new cable, with the exception of joint bays.
- Joint bays shall be opened for as short a time as possible prior to commencement of jointing.
- All 11kV and 33kV joints and associated cables shall be blinded before the Jointer leaves site.
- LV joints and associated cables shall preferably be blinded before the Jointer leaves site and by the next day at the latest.

## **20. CABLE TESTING AND COMMISSIONING**

Cables shall be tested in accordance with SUB-02-613 prior to energisation.

## 21. APPENDIX 1 – REQUIRED INSTALLATION PARAMETERS

### 21.1 General

The requirements of this section must be complied with for all cables, up to and including 33kV, which are installed with the intention that they will become part of SPEN's network.

### 21.2 Bedding Materials

All cables and ducts shall be bedded and blinded as defined below:

#### 21.2.1 Definitions

##### *Soft finefill material*

Soft finefill material shall be as per ENA TS 97-1, of consistent composition under all conditions of humidity and temperature and shall not contain any readily visible foreign matter such as pieces of clay or organic detritus. The material shall not contain any sharp stones or flints.

##### *Selected sand backfill*

Selected sand backfill shall be as per ENA TS 97-1, of consistent composition and shall not contain any readily visible foreign matter such as pieces of clay or organic detritus. Not less than 95% by weight of the material shall pass through a British Standard 5mm sieve. The material shall not contain any sharp stones or flints.

The dry relative density of the selected sand backfill shall not be less than 1.6 when determined in accordance with Appendix A of ENA TS 97-1.

#### 21.2.2 LV Cables

All LV cables shall be surrounded by a minimum of 50mm of soft finefill material.

#### 21.2.3 11kV Cables

All 11kV cables shall be surrounded by a minimum of 75mm of either soft finefill material or selected sand backfill.

#### 21.2.4 33kV Cables

All 33kV cables shall be surrounded by a minimum of 75mm of selected sand backfill.

### 21.3 Maximum Pulling Tensions

Maximum permissible pulling tensions for each cable type are given below. These tensions must not be exceeded under any circumstances. Efforts should always be made to achieve lower figures by careful route design, setting out of the work and positioning of the cable drum.

#### LV & 11kV Cables

	Maximum pulling tension (kN)				
Conductor size (mm <sup>2</sup> )	95 Al	185 Al	240 Al	300 Al	300 Cu
3-phase waveform	2.89	7.78	8.67	9.79	-
11kV 1-core xlpe	2.85	5.55	-	9.0	15.0
11kV 3-core xlpe	3.91	6.36	-	9.79	-

#### 33kV Cables

	Maximum pulling tension (kN)				
Conductor size (mm <sup>2</sup> )	150	240	400	500	630
Aluminium Conductor	4.0	5.5	8.0	-	-
Copper Conductor	5.5	8.0	-	14.6	18.0

## 21.4 Minimum Bending Radii

Minimum bending radii to which cables in new condition may be bent are given below for the installation conditions stated.

The following installation conditions apply:

*Dynamic* – When cables are being pulled in.

*Static* – When cables are bent in-situ adjacent to joints or terminations.

Under no circumstances must the minimum dimensions given below be infringed, as damage will be caused to the cable's insulation and screening systems resulting in premature failure.

Cable Type		Conductor size (mm <sup>2</sup> )							
		95	150	185	240	300	400	500	630
		Minimum Bending Radius (mm)							
Three phase waveform	<i>Dynamic</i>	500	-	650	850	850	-	-	-
	<i>Static</i>	240	-	400	540	540	-	-	-
11kV 1-core xlpe	<i>Dynamic</i>	560	-	650	-	750	-	900	-
	<i>Static</i>	420	-	490	-	560	-	680	-
11kV 3-core xlpe	<i>Dynamic</i>	600	-	750	-	900	-	-	-
	<i>Static</i>	500	-	600	-	750	-	-	-
33kV 1-core xlpe	<i>Dynamic</i>	-	900	-	950	-	1050	1150	1250
	<i>Static</i>	-	650	-	700	-	750	850	950

## 21.5 Depth of Cover

Cables and ducts shall be installed so as to provide the minimum depth of cover detailed below.

Surface Type	Voltage		
	33kV	11kV	Low Voltage
	Minimum Depth of Cover (mm)		
Unmade ground, footways & footpaths	775	600	450
Roads	775	700	600
Cultivated ground inc. gardens	775	700	600
Agricultural land	910	910	910

**NOTE:** In certain situations it may not be possible to achieve the minimum cover detailed above. In these cases, it will be necessary to:

- Minimise the length over which minimum depth is not attained.
- Install additional mechanical protection as appropriate for the location and circumstances.
- Install additional warning, for example in the form of posts or signs, appropriate to the location and circumstances.
- Ensure that the cable records clearly detail the depth and extent of the shallow section of cable.

**On railway property**, other than across or near railway track, normal depth of cover shall be used subject to a minimum depth to comply with the standard railway wayleave agreement.

## 21.6 Position of Warning Tapes, Protection Tapes and Protection Tiles

Approved warning tapes shall be installed 200mm above all low voltage cables and joints.

Approved protection tapes shall be installed 250mm above all 11kV cables and joints. Where an 11kV cable is installed directly below another cable, its protection tape shall be installed immediately below the higher cable.

Approved ENA TS 12-23 Class 2 protection tiles shall be installed 75mm above all 33kV cables and 33kV joints.

Where existing warning markers on any cable are disturbed or removed during excavation, these markers shall be replaced or renewed as appropriate.

Where existing cables without marker tapes or tiles (including LV cables) are uncovered during the course of excavation, new marker tape or tile shall be installed over the complete exposed section of the existing cables. **This is necessary to comply with ESQC Regulations.**

### 21.7 Multiple Cable Spacing

Minimum spacing between adjacent cables is as shown below:

33kV	450mm
11kV	300mm
LV main	250mm
LV service	100mm

These spacings are the minimum required to allow for future access and jointing works. They do not take into consideration any ratings requirements. The actual minimum spacing requirement may be greater than those given above depending on ratings requirements and the proximity of other cables or sources of heat.

For single core trefoil installations, the dimensions above shall be measured between centres of the closet cores in the trefoil groups.

### 21.8 Joint Bay Dimensions

Minimum required joint bay dimensions are shown below. In all cases, the joint bay shall be excavated to a depth of 200mm below the bottom of the cables to allow adequate access for jointing:

<b>Voltage</b>	<b>Joint Type</b>	<b>Joint bay minimum dimensions (length x width) m</b>	<b>SPEN Drawing Number</b>
LV	All service cable joints	0.9 x 0.6	SP4081856
	All mains joints and service branch joints except breech joint with 240mm <sup>o</sup> cables or larger	1.2 x 0.9	SP4081857
	Breech joint with 240mm <sup>o</sup> cables or larger	1.5 x 0.9	SP4081858
11kV	All 11kV joints except breech and loop joints	2.2 x 1.2	SP4081859
	11kV breech and loop joints	2.5 x 1.2	SP4081860
33kV	All 33kV joints	2.7 x 1.5	SP4081861

**21.9 Ducts**

All ducts for installation on the SPEN network shall be new and classified as Approved on the approved equipment register, CAB-06-001.

Where ducts are specified the recommended internal diameters are as shown below, these minimum duct diameters should be used wherever possible to minimise circulating currents for single core installations. Larger diameter ducts shall only be used in situations where the route is unusually tortuous.

<b>Cable Type</b>	<b>Minimum inside diameter of duct (mm)</b>
LV mains cable	100
11kV 1-core cables and 95mm <sup>2</sup> 3-core cable	100
11kV 185mm <sup>2</sup> and 300mm <sup>2</sup> 3-core cables	150
33kV cables up to and including 400mm <sup>2</sup>	100
33kV cables above 400mm <sup>2</sup>	150

Where single core cables are to be installed in individual ducts the ducts shall be installed in touching trefoil arrangement. In this situation the use of ducts of a larger diameter than necessary should be avoided in order to minimise de-rating of the installed cables due to sheath circulating currents.

After installation of ducts the installer shall:

- Confirm that they are correctly aligned by pulling through a mandrel of a diameter slightly less than that of the duct.
- Clean them by drawing through a suitable cleaning pig.
- Install a non-perishable draw rope.
- Seal the duct mouths temporarily until they are required for cable installation.

Where additional ducts are to be left empty for future use, they shall be identified by laying polythene marker tape through the duct. In unmade ground the ends of the marker tape shall be brought out above ground level.

Where cables enter a building via ducts the duct entry, both internal and external to the duct wall, shall be sealed against the ingress of gas and moisture by an approved method. The SPEN approved equipment register, CAB-06-001 details Approved products.

**21.10 As Laid Records**

As laid records shall be provided in accordance with the requirements of SPEN document BUPR-22-015.



## 22. APPENDIX 2 – SEALING WIRE ARMoured PLASTIC SHEATHED PILOT AND TELECOMS CABLES

### 22.1 Background

SPEN audits have highlighted that wire armoured, plastic sheathed pilot and telecoms cables have shown signs of water ingress even though they had been sealed. The main reason for this is because only the outer sheath of the cable has been sealed. These types of cables have an inner and outer plastic sheath that **BOTH** require to be sealed from moisture as water can travel between these sheaths along the wire armours. The following guidance steps have been established to enable staff to apply moisture barrier tape and cold shrink end caps to effectively seal both inner and outer sheaths of the pilot/telecoms cables.

### 22.2 Procedure

Mark and remove the outer sheath and wire armours 20mm from the end of the cable, as shown in the steps in Figure 1.



Figure 1 – Sealing Wire Armoured Plastic Sheathed Pilot and Telecoms Cables Steps 1 to 3

Apply a patch of butyl mastic over the end of the cable then build up over the inner sheath to the diameter of the outer sheath with the mastic tape and finish 40mm from the end of the cable, as shown in the steps in Figure 2.



Figure 2 - Sealing Wire Armoured Plastic Sheathed Pilot and Telecoms Cables Steps 4 to 6

Uncoil the first 3 or 4 spirals of the plastic insert from the end cap and fit over cable and butyl tape. Remove the remaining spirals from the end cap to effectively seal the cable, as shown in the steps in Figure 3.



Figure 3 - Sealing Wire Armoured Plastic Sheathed Pilot and Telecoms Cables Steps 7 to 9