

Typical Link Box Bell Housing covers



The above images highlight 2 types of SP Energy Networks link box bell housing covers which are situated beneath link box covers which can be found in many footpaths in the East of Scotland area (Edinburgh, Lothian's, Borders, Fife, & Falkirk).

Link box housing covers should only be removed by ScottishPower electrically trained engineers. With many street scape projects taking place on occasions, there may be conflicts with footpath levels and existing link box covers.

All Cable Record enquiries should be addressed to:

SP Energy Networks (North)
Data Management
(Correspondence)
55 Fullerton Drive
Cambuslang
Glasgow G32 8FD
t: 0141 567 4155 or 0141 567 4455
e: Requestforplansscotland
@scottishpower.com

SP Energy Networks (South)
Data Management
(Correspondence)
North Cheshire Trading Estate
Prenton Way
Prenton
Birkenhead CH43 3ET
t: 0151 609 2373
e: Requestforplansmanweb
@manweb.co.uk

All Cable Deviation Requests /Service Alterations enquiries should be addressed to:

SP Energy Networks (North)
Customer Connections
55 Fullerton Drive
Cambuslang
Glasgow G32 8FA
t: 0141 614 9997

SP Energy Networks (South)
Customer Connections
PO Box 290
Lister Drive
Liverpool L13 7HJ
t: 0151 221 2110

Emergency contact

In an emergency, or if there is any damage to SP Energy Networks cables or plant, call the appropriate number:



**SP Energy Networks
North**
*Central & Southern
Scotland*
0845 272 7999

**SP Energy
Networks
South**
*Cheshire,
Merseyside
& North Wales*
0845 272 2424



Damage To Bell Housing In Electricity Network Boxes



The above images highlight a situation which has increased over recent years with local authorities carrying out numerous streetscape works. The images demonstrate link box bell housing covers which cover the underground electrical network.

The link box covers have been removed to gain access to the bell apparatus should never be interfered with at any time, the consequences of contact with the electrical network can lead to serious injuries or in some cases death.

**Always Seek Advice Regarding ScottishPower Apparatus Prior to Works Progressing
Contact 0845 273 4444**

All Cable Record enquiries should be addressed to:

SP Energy Networks (North)
Data Management
(Correspondence)
55 Fullerton Drive
Cambuslang
Glasgow G32 8FD
t: 0141 567 4155 or 0141 567 4455
e: Requestforplansscotland@scottishpower.com

SP Energy Networks (South)
Data Management
(Correspondence)
North Cheshire Trading Estate
Prenton Way
Prenton
Birkenhead CH43 3ET
t: 0151 609 2373
e: Requestforplansmanweb@manweb.co.uk

All Cable Deviation Requests /Service Alterations enquiries should be addressed to:

SP Energy Networks (North)
Customer Connections
55 Fullerton Drive
Cambuslang
Glasgow G32 8FA
t: 0141 614 9997

SP Energy Networks (South)
Customer Connections
PO Box 290
Lister Drive
Liverpool L13 7HJ
t: 0151 221 2110

Emergency contact

In an emergency, or if there is any damage to SP Energy Networks cables or plant, call the appropriate number:

SP Energy Networks North

Central & Southern Scotland

0845 272 7999

SP Energy Networks South

Cheshire, Merseyside & North Wales

0845 272 2424

