



Figure 1.3: Site Plan - Temporary Tower Diversion Proposals

- Proposed tower
- Proposed 400kV Overhead Line (OHL) ZV diversion
- ZV Diversion temporary alignment
- Indicative temporary access track
- Temporary working area
- Proposed Redshaw Substation
- Existing tower
- Existing tower to be removed
- Existing 400kV Overhead Line (OHL)
- Existing 400kV Overhead Line (OHL) to be removed

**Note:**  
The temporary alignment is expected to be in place for a period of 3 years and then the diversion will be turned into the Proposed Redshaw substation and the temporary alignment between towers ZV110A and ZV110B will be removed.

Proposed Redshaw substation subject to a separate consenting process