

12.

Appendices

Appendix 12.1 Noise Perception and Terminology

Noise Perception and Terminology

Between the quietest audible sound and the loudest tolerable sound there is a million to one ratio in sound pressure (measured in pascals, Pa). Because of this wide range a noise level scale based on logarithms is used in noise measurement called the decibel (dB) scale. Audibility of sound covers a range of approximately 0 to 140 dB.

The human ear system does not respond uniformly to sound across the detectable frequency range and consequently instrumentation used to measure noise is weighted to represent the performance of the ear. This is known as the 'A weighting' and annotated as dB (A) or L_{pA} dB. Table 10.1 below lists the sound pressure level in dB (A) for common situations.

The noise level at a measurement point is rarely steady, even in rural areas, and varies over a range dependent upon the effects of local noise sources. Close to a busy road, the noise level may vary over a range of 5 dB(A), whereas in a suburban area this may increase up to 40 dB(A) and more due to the multitude of noise sources in such areas (cars, dogs, aircraft etc.) and their variable operation. Furthermore, the range of night-time noise levels will often be smaller and the levels significantly reduced compared to daytime levels.

Table 10.1 Noise Levels for Common Situations

Typical noise level, dB(A)	Example
0	Threshold of hearing
30	Rural area at night, still air
40	Public library, refrigerator humming at 2m
50	Quiet office, no machinery
60	Normal conversation
70	Telephone ringing at 2m
80	General factory noise level
90	Heavy goods vehicle from pavement
100	Pneumatic Drill at 5m
120	Discotheque – 1m in front of loud speaker
140	Threshold of pain

The equivalent continuous A-weighted sound pressure level, L_{Aeq} dB (or L_{eq} dBA), is the single number that represents the average sound energy measured over that period. The L_{Aeq} is the sound level of a notionally steady sound having the same energy as a fluctuating sound over a specified measurement period.

When considering environmental noise, it is necessary to consider how to quantify the existing noise (the ambient noise) to account for these second-to-second variations. A parameter that is widely accepted as reflecting human perception of the ambient noise is the background noise level, L_{A90} . This is the noise level exceeded for 90% of the measurement period and generally reflects the noise level in the lulls between individual noise events. Over a one-hour period, the L_{A90} will be the noise level exceeded for 54 minutes.

Human subjects are generally only capable of noticing changes in steady levels of no less than 3 dB(A). It is generally accepted that a change of 10 dB(A) in an overall, steady noise level is perceived to the human ear as a doubling (or halving) of the noise level. (These findings do not necessarily apply to transient or non-steady noise sources such as changes in noise due to changes in road traffic flow, or intermittent noise sources).


Appendix 12.2 Baseline Survey Measurement Locations

Figure 12.1. Noise Measurement Locations



Appendix 12.3 Proposed Substation Layout

Figure 12.2 Proposed Substation Layout



Appendix 12.4 Baseline Survey Measurements

Table 1 ML1 Survey Location Details

ML1	Description
Location description, what 3 words location and OS grid reference (Easting/Northing)	///dolphins.calibrate.focal 292973, 689210
Monitoring date and time	01/08/2024 12:35 to 05/08/2024 12:35
Monitoring height above ground	1.5m
Distance to nearest building façade	Greater than 3.5m
Sound Level Meter and Serial No.	Rion NL-52 00386766
Field Calibrator and Serial No.	Brüel & Kjær 4231 2217876
Weather station used	Davis Vantage Vue DAV 6250
Daytime description of the sound climate	The dominant sound source was birdsong and intermittent road traffic noise.



Figure 1 ML1 Equipment Setup

Table 2 ML1 Summary of Each Measurement Period

Period	Date	L_{Aeq} (logarithmic mean)	L_{AFmax} (maximum)	L_{A90} (mean)
Day (12:35-19:00)	01/08/2024	50	85	44
Day (07:00-19:00)	02/08/2024	55	82	44
Day (07:00-19:00)	03/08/2024	48	74	43
Day (07:00-19:00)	04/08/2024	49	73	43
Day (07:00-12:35)	05/08/2024	51	73	45
Day-Evening (07:00 – 23:00)	01/08/2024	49	85	42
Day-Evening (07:00 – 23:00)	02/08/2024	54	82	43
Day-Evening (07:00 – 23:00)	03/08/2024	48	75	42
Day-Evening (07:00 – 23:00)	04/08/2024	49	73	43
Day-Evening (07:00 – 23:00)	05/08/2024	51	73	45
Evening (19:00-23:00)	01/08/2024	47	67	40
Evening (19:00-23:00)	02/08/2024	45	70	40
Evening (19:00-23:00)	03/08/2024	46	75	39
Evening (19:00-23:00)	04/08/2024	48	73	42
Night (23:00-07:00)	01/08/2024	45	78	33
Night (23:00-07:00)	02/08/2024	44	76	32
Night (23:00-07:00)	03/08/2024	42	69	31
Night (23:00-07:00)	04/08/2024	46	70	38

Table 3 ML1 Overall Summary

Period	L_{Aeq} (logarithmic average)	L_{AFmax} (maximum)	L_{A90} (mean)	L_{A90} (mode)
Day	51	85	44	45
Day-Evening	51	85	43	45
Evening	46	75	40	38
Night	44	78	33	32




Figure 2 ML1 Time Series Data

Table 4 ML2 Survey Location Details

ML2	Description
Location description, what 3 words location and OS grid reference (Easting/Northing)	///fattening.hems.share 292973, 689210
Monitoring date and time	01/08/2024 14:15 – 05/08/2024 13:45
Monitoring height above ground	1.5m
Distance to nearest building façade	Greater than 3.5m
Sound Level Meter and Serial No.	Rion NL-52 00386764
Field Calibrator and Serial No.	Brüel & Kjær 4231 2217876
Weather station used	Davis Vantage Vue DAV 6250
Daytime description of the sound climate	Distant, intermittent road traffic noise.



Figure 3 ML2 Equipment Setup

Table 5 ML2 Summary of Each Measurement Period

Period	Date	L_{Aeq} (logarithmic mean)	L_{AFmax} (maximum)	L_{A90} (mean)
Day (14:15-19:00)	01/08/2024	48	72	44
Day (07:00-19:00)	02/08/2024	48	80	45
Day (07:00-19:00)	03/08/2024	51	74	46
Day (07:00-19:00)	04/08/2024	48	66	44
Day (07:00-13:45)	05/08/2024	49	84	46
Day-Evening (07:00 – 23:00)	01/08/2024	47	72	41
Day-Evening (07:00 – 23:00)	02/08/2024	47	80	43
Day-Evening (07:00 – 23:00)	03/08/2024	50	74	44
Day-Evening (07:00 – 23:00)	04/08/2024	47	70	44
Day-Evening (07:00 – 23:00)	05/08/2024	49	84	46
Evening (19:00-23:00)	01/08/2024	43	64	38
Evening (19:00-23:00)	02/08/2024	45	59	40
Evening (19:00-23:00)	03/08/2024	44	70	38
Evening (19:00-23:00)	04/08/2024	46	70	43
Night (23:00-07:00)	01/08/2024	41	67	33
Night (23:00-07:00)	02/08/2024	40	66	32
Night (23:00-07:00)	03/08/2024	39	61	31
Night (23:00-07:00)	04/08/2024	46	73	40

Table 6 ML2 Overall Summary

Period	L_{Aeq} (logarithmic average)	L_{AFmax} (maximum)	L_{A90} (mean)	L_{A90} (mode)
Day	49	84	45	46
Day-Evening	48	84	44	46
Evening	44	70	39	41
Night	41	73	33	34




Figure 4 ML2 Time

Appendix 12.5 Acoustic Modelling Details

Prediction Methodology

Modelling of sound levels from the Proposed Development has been undertaken using CadnaA acoustic modelling software. This software implements the sound propagation calculation methodology set out in the ISO 9613-2:2024 – ‘Attenuation of sound during propagation outdoors’. The propagation model described in this standard provides for the prediction of sound pressure levels based on either short-term downwind (i.e. worst case) conditions or long-term overall averages. The highest sound levels at NSRs occur under down wind conditions (wind blowing 1 to 5 m/s from the site towards the nearby receptors), and these have been adopted within the model. When the wind is blowing in the opposite direction, sound levels may be significantly lower than those predicted. The ISO propagation model calculates the predicted sound pressure level by taking the source sound power level for each source and subtracting a number of attenuation factors according to the following:

$$\text{Predicted Sound Level} = L_{WA} + D - A_{geo} - A_{atm} - A_{gr} - A_{bar} - A_{misc}$$

These factors are discussed in detail below.

The Sound Power Level (L_{WA}) defines the total acoustic power radiated by a noise source expressed in decibels (dB re 1 pW).

The directivity factor (D) allows for an adjustment to be made where the sound radiated in the direction of interest is higher than that for which the sound power level is specified. No directivity factor is considered within this assessment.

The geometrical divergence (A_{geo}) accounts for spherical spreading of the sound from the source within free-field conditions. Different sources at the Installation have been modelled to take account of their geometry, as area, line or point sources. The divergence factor is calculated from the distance from the source to the receiver, and the relationship between the attenuation provided and distance is dependent on the type of sound source assumed.

The atmospheric absorption factor (A_{atm}) considers the attenuation offered by the atmosphere as a result of the conversion of sound to heat. The degree of attenuation is dependent on the relative humidity and temperature of the air through which the sound is travelling and is frequency dependent. Increasing attenuation occurs towards the higher frequencies of sound.

Modelling parameters have assumed an ambient temperature of 10 °C and 70% relative humidity which are found to result in worst case noise propagation. The corresponding atmospheric attenuation factors are summarised below in Table 1.

Table 1 Atmospheric Attenuation (dB/km) at 10 °C and 70% Relative Humidity

Octave Band Centre Frequency / Hz	63	125	250	500	1k	2k	4k	8k
Atmospheric Absorption Coefficient dB / km	0.122	0.411	1.04	1.93	3.68	9.66	32.8	117

The ground effect (A_{gr}) is the result of sound reflected by the ground interfering with the sound propagating directly from source to receiver, and the interaction of the sound with porous and absorptive ground cover. The prediction of ground effects depends on the source height, receiver height, propagation height between the source and receiver and the ground conditions.

The ground conditions are described according to a variable defined as G , which varies between 0 for 'hard' ground (includes paving, water, ice, concrete and any locations with low porosity) and 1 for 'soft' ground (includes ground covered by grass, trees or other vegetation).

The effect of any barrier or topographical obstruction (A_{bar}) between the sound source and the receiver position is that sound will be reduced according to the relative heights of the source, receiver and barrier and the frequency spectrum of the sound.

Acoustic Modelling Input Data

All plant has been modelled as point sources which is considered appropriate due to the distance to noise sensitive receptors. The sound power levels for proposed new plant items assessed in this report are provided in the following table. Receiver points are modelled at 1.5 m for the ground floor and 4 m for the first floor. Point sources are positioned in the centre of the top of each item of plant. Heights are provided in the table below.

Table 2 Sound Power Level of New Plant Items

New Plant Item	Sound Power Level L_{wA} (dB)	Point Source Height (m)
2x Power Transformer With Cooler Unit	87	7
2x Earthing / Auxiliary Transformer	70	1.5
2x Shunt Reactor	83	3.9
1x Standby Diesel Generator (Rural option)	102*	1.6

Note: *The standby diesel generator noise level was provided as a sound pressure level of 85 dBA at 1 m which was converted to a sound power level via the conformal surfaces method.

Table 0.1. Sound Power Levels (dB per unit) at Third-Octave Band Centre Frequency (Hz)

Unit	50	63	80	100	125	160	200	250	315	400	500	630	800	1k	1.25k	1.6k	2k	2.5k	3.15k	4k	5k	6.3k	8k	10k	Total (dB L _A)
Power Transformer With Cooler Unit	74	73	74	92	74	63	74	63	67	75	61	63	60	60	60	59	56	57	59	77	85	73	54	52	87
Earthing / Auxiliary Transformer	57	56	57	75	57	46	57	46	50	58	44	46	43	43	43	42	39	40	42	60	68	56	37	35	70
Shunt Reactor	70	69	70	88	70	59	70	59	63	71	57	59	56	56	56	55	52	53	55	73	81	69	50	48	83
Standby Diesel Generator (rural option)*	-	103	-	-	100	-	-	104	-	-	98	-	-	97	-	-	93	-	-	84	-	-	75	-	102

*Note: The standby diesel generator was modelled using octave bands.

Appendix 12.6 Predicted Internal Noise Levels

Table 0.1 Predicted noise break in and noise ratings assuming the substation is operational with a rural standby diesel generator

NSR	Assessment Period	Predicted External Noise Break in L_{eq}							Predicted Internal Noise Level $L_{Aeq,T}$ (63 Hz – 4 kHz)	Predicted Internal Noise Rating	Meets NR 25 (and NR 35) (Y/N)
		63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz			
NSR1 First Floor	Day	26	21	20	20	19	8	-8	22	NR 19	Y
	Night	26	24	23	21	20	9	-6	23	NR 20	Y
NSR2 First Floor	Day	26	22	20	20	20	9	-7	23	NR 20	Y
	Night	27	25	23	21	21	10	-6	24	NR 21	Y
NSR3 First Floor	Day	22	18	16	15	14	1	-21	17	NR 14	Y
	Night	23	21	19	16	16	3	-19	19	NR 15	Y

