



## 1 SCOPE

This document details the application of SOP 7A issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### **4 SOP DETAILS**

**TYPE:** Lucy FRMU Mk1 & Mk2.

**ORIGINATING REC:** East Midlands Board

**DATE:** 12/10/79

**NO. INSTALLED IN MANWEB:** 500

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Live operation banned until modified.

**REASON:** Defective oil switch mechanism allowed slow closing.

**UPDATE:**

**REMEDIAL ACTION:** Modification required. See P.S.B. No 12.