



## 1 SCOPE

This document details the application of SOP 9 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** Switchgear & Cowan 11 kV IF Oil Switch.

**ORIGINATING REC:** East Midlands Board

**DATE:** 2/1/80

**NO. INSTALLED IN MANWEB:** 0

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Dead Operation Only (None on Manweb System).

**REASON:** Fixed pin of handle operating mechanism wrongly fitted,  
causing leaf spring handle not to operate correctly.

**UPDATE:**

**REMEDIAL ACTION:** Modification required.