



1 SCOPE

This document details the application of SOP 11 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: All Dependant Manual Oil Switches.

ORIGINATING REC: East Midlands Electricity Board

DATE: 25/6/80

NO INSTALLED IN MANWEB: 1300
NO. INSTALLED IN SCOTLAND

STATUS: Dead Operation Only, until Modified. (All known units in Manweb modified restriction does not therefor apply in Manweb)

REASON: No spring assistance. Operation had to be positive, efficient, without hesitation and not re-opened.

UPDATE:

REMEDIAL ACTION: Modification to spring assisted with 3 second delay and replace 94 units. Label "DEAD OPERATION ONLY" and lock unmodified units.