



## 1 SCOPE

This document details the application of SOP 15 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** Yorkshire 11 kV Tyke MkII R.M.U., SO-FM O.S.

**ORIGINATING REC:** South Eastern Electricity Board

**DATE:** 27/11/80

**NO. INSTALLED IN MANWEB:** 0

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Live Operational Ban (None on Manweb System).

**REASON:** Reduced clearance between main switch blades and earth switch brass stops due to distortion.

**UPDATE:**

**REMEDIAL ACTION:** Live operational ban. Cable connection to be dead when switch in off position. Modification.