



## 1 SCOPE

This document details the application of SOP 21 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** G.E.C. 11 kV T3/OF & T3/AF R.M.U.

**ORIGINATING REC:** Yorkshire Electricity Board

**DATE:** 7/9/82

**NO. INSTALLED IN MANWEB:** 0

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Restriction (None on Manweb System).

**REASON:** Spring mechanism and indicator moved while switch blades remained stationary, due to failure of brazed joint.

**UPDATE:**

**REMEDIAL ACTION:** Modification required.