



1 SCOPE

This document details the application of SOP 23 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: 11 kV Corrugated Aluminium Sheathed Cable.
RACHEM heat shrink termination

ORIGINATING REC: North Eastern Electricity Board

DATE: 12/8/83

NO. INSTALLED IN MANWEB:N/A

NO. INSTALLED IN SCOTLAND:

STATUS: RESTRICTION (decision taken not to apply in Manweb).

REASON: Heat shrink terminations failed due to crotch seal failure
and use of excessive heat when plumbing gland.

UPDATE:

REMEDIAL ACTION: