



1 SCOPE

This document details the application of SOP 30 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

| Issue Date | Issue No | Author | Amendment Details |
|--------------|----------|----------------|---|
| October 2000 | 1 | Esther Stewart | Initial Issue in New Format: 2 Page Document |

3 ISSUE AUTHORITY

| Author | Owner | Issue Authority |
|----------------|--------------|--|
| Esther Stewart | Roger Bracey | Roger Bracey Group Head, Standards |



4 SOP DETAILS

TYPE: GEC FG1 145 kV SF6 C.B.

ORIGINATING REC: South of Scotland Electricity Board

DATE: 13/8/84

NO. INSTALLED IN MANWEB: 6

NO. INSTALLED IN SCOTLAND:

STATUS: All known units in Manweb modified.

REASON: Slow closing condition possible due to leaking 'O' ring seal.

UPDATE:

REMEDIAL ACTION: