



## 1 SCOPE

This document details the application of SOP 45 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** Johnson & Phillips/GEC PDB & PDB-M/JPBF 11  
kV O.C.B.

**ORIGINATING REC:** MANWEB

**DATE:** 6/4/87

**NO. INSTALLED IN MANWEB:** 1873

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Live operating banned until modified.

**REASON:** Explosion of o.c.b. tank, due to contaminated oil.

**UPDATE:**

**REMEDIAL ACTION:** Inspection and modification required. Instructions issued in  
1987. See PSBs 2, 3, 6, 7, 9, 10, 11, 16, 21.