



## 1 SCOPE

This document details the application of SOP 63 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

| Issue Date   | Issue No | Author         | Amendment Details                               |
|--------------|----------|----------------|---|
| October 2000 | 1        | Esther Stewart | Initial Issue in New Format:<br>2 Page Document |

## 3 ISSUE AUTHORITY

| Author         | Owner        | Issue Authority                                |
|----------------|--------------|--|
| Esther Stewart | Roger Bracey | Roger Bracey<br>Group Head, Standards<br>..... |



#### 4 SOP DETAILS

**TYPE:** South Wales Switchgear IF4X 11 kV Oil Switches

**ORIGINATING REC:** MEB

**DATE:** 16/9/88

**NO. INSTALLED IN MANWEB:** 0

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Ban (None on Manweb System).

**REASON:** Incorrectly fitted waterproof cowlings and gasket seals allowed water ingress, resulting in an explosion.

**UPDATE:**

**REMEDIAL ACTION:** Inspection required.