



1 SCOPE

This document details the application of SOP 69 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Whipp & Bourne CV 11 kV VCB

ORIGINATING REC: North of Scotland Hydro Electricity Board

DATE: 22/12/88

NO. INSTALLED IN MANWEB: 2

NO. INSTALLED IN SCOTLAND:

STATUS: Live operation banned until modified.

REASON: Loose screws in busbar segregational barrier interlock could allow steel bar to fall onto busbar contact.

UPDATE:

REMEDIAL ACTION: Inspection required. Loctite screws to secure.