



## 1 SCOPE

This document details the application of SOP 74 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** Whipp & Bourne CV 11 kV VCB

**ORIGINATING REC:** NORWEB

**DATE:** 30/3/89

**NO. INSTALLED IN MANWEB:**2

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Live operation banned until modified.

**REASON:** See SOP 69 Pivot pin and interlock bar found detached.

**UPDATE:**

**REMEDIAL ACTION:** See SOP 69.