



1 SCOPE

This document details the application of SOP 81 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Long & Crawford J3 & J4GF3

ORIGINATING REC: East Midlands

DATE: 5/5/89

NO. INSTALLED IN MANWEB: 195

NO. INSTALLED IN SCOTLAND

STATUS: Operation restricted.

REASON: See SOP 78 and 79. Crazed sight glass allowed moisture ingress.

UPDATE:

REMEDIAL ACTION: See SOP 79. See P.S.B. No. 17.