



## 1 SCOPE

This document details the application of SOP 83 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** Reyrolle JKSS 11 kV R.M.U.

**ORIGINATING REC:** MEB

**DATE:** 12/5/89

**NO. INSTALLED IN MANWEB:** 45

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Restriction : Circuit must be proved dead before earth switch is closed.

**REASON:** Mechanism stiff due to seizing bearings on earth switch.  
Difficult to operate OFF to EARTH.

**UPDATE:**

**REMEDIAL ACTION:** Maintenance required. See P.S.B. No. 45.