



1 SCOPE

This document details the application of SOP 89 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Long & Crawford T3GF3 & T4GF3 11 kV R.M.U.

ORIGINATING REC: SWEB

DATE: 3/11/89

NO. INSTALLED IN MANWEB: 195

NO. INSTALLED IN SCOTLAND:

STATUS: Live operation banned until inspected.

REASON: See SOP 90. Two painters injured while preparing switchgear for painting.

UPDATE:

REMEDIAL ACTION: See SOP 90 and PSB 53.