



1 SCOPE

This document details the application of SOP 99 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: GEC Alsthom FGI(E) 145 kV SF6 C.B.

ORIGINATING REC: NGC

DATE: 11/6/90

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: No restriction in Manweb

REASON: Interrupter unit failure

UPDATE:

REMEDIAL ACTION: Access restricted in some cases, Manweb not affected.