



## 1 SCOPE

This document details the application of SOP 108 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** Yorkshire Tyke IIA 11KV RMU

**ORIGINATING REC:** Guernsey

**DATE:** 7/6/91

**NO. INSTALLED IN MANWEB:** 3

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Live Operation Banned.

**REASON:** Water ingress into cable box.

**UPDATE:**

**REMEDIAL ACTION:** All units to be replaced.