



1 SCOPE

This document details the application of SOP 114 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: S&C TYPE ID 11kV O/S

ORIGINATING REC: London Electricity

DATE: 13/9/91

NO. INSTALLED IN MANWEB:0

NO. INSTALLED IN SCOTLAND:

STATUS: Ban (None on Manweb system)

REASON: Flashover during operation

UPDATE:

REMEDIAL ACTION: Under Investigation