



## 1 SCOPE

This document details the application of SOP 117 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** GEC JB424 33kV OCB

**ORIGINATING REC:** Northern Ireland Electricity

**DATE:** 11/5/92

**NO. INSTALLED IN MANWEB:** 32

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Operation Restricted

1. Live operation of the switchgear must only be carried out using remote control.
2. Access to the area where Live switchgear of this type is situated shall be restricted to essential operational activities only.
3. All the bushings in the type JB424 ocb's, without a seal around the top cap must be refurbished before removal of SOP 117.

**REASON:** Under Investigation

**UPDATE:**

**REMEDIAL ACTION:**