



1 SCOPE

This document details the application of SOP 118 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: GEC 20-80A single phase credit meter type
C11B2A/H two rate credit meter type C11B2A/RH
with serial numbers K91J or K92J.

ORIGINATING REC: SWEB

DATE: 1/7/92

NO. INSTALLED IN MANWEB: Approx 5000
NO. INSTALLED IN SCOTLAND:

STATUS: Restriction.

1. All meters of the above type to be checked before installation as per instructions to be issued by Metering & Telecoms Manager.
2. Dead working remains our current practice.

REASON: Loose bolt in meter caused disruptive failure.

UPDATE:

REMEDIAL ACTION: