



1 SCOPE

This document details the application of SOP 147 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: ABB Sentinal SF6 insulated 12kV VCB
RMU

ORIGINATING REC: Manweb

DATE: 24/5/95

NO. INSTALLED IN MANWEB: 12
NO. INSTALLED IN SCOTLAND:

STATUS: Restriction

REASON: Risk of the manual closing mechanism fouling the electrical tripping mechanism and thus preventing electrical tripping of circuit breaker.

UPDATE: 06/04/98 All remedial work in Manweb believed complete.

REMEDIAL ACTION: Live Manual Closing of Circuit Breaker Prohibited until further notice.