



1 SCOPE

This document details the application of SOP 157 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: HAWKER SIDDELEY FALCON BETA RMU

ORIGINATING REC: LONDON ELECTRICITY

DATE: 22/12/95

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Ban on live operation of ring switches. (None in MANWEB).

REASON: Following an "open" operation, one phase of a ring switch was found to be still closed.

UPDATE:

REMEDIAL ACTION: Investigations ongoing