



1 SCOPE

This document details the application of SOP 158 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: CROMPTON PARKINSON ULA1 & ULB1
CBs (excl. 1200A units)

ORIGINATING REC: SWEB

DATE: 05/01/96

NO. INSTALLED IN MANWEB: 0
NO. INSTALLED IN SCOTLAND:

STATUS: Restriction on operation of earthing extensions.

REASON:

UPDATE:

REMEDIAL ACTION: See SWEB instructions