



1 SCOPE

This document details the application of SOP 174 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Long & Crawford TYPE RT SF6 11kV RMU
TEE OFF Circuit Breaker.

ORIGINATING REC: Scottish Hydro Electric

DATE: 09/01/97

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Ban on Live Operation of TEE OFF Circuit Breaker
15/04/97 SOP WITHDRAWN.

REASON: Circuit breaker fails to latch during closing operations.

UPDATE:

15/04/97 The cb mechanism has been redesigned and satisfactorily tested by the manufacturer. All units are to be returned to the manufacturer for modification. This operational restriction is WITHDRAWN.

REMEDIAL ACTION:

Manufacturer has accepted that modifications are necessary to the operating mechanism. The one unit so far purchased by MANWEB will be returned to be factory modified. All units purchased in future will of course be modified units.