



1 SCOPE

This document details the application of SOP 175 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: ABB TYPE LTB GCB. (132KV)

ORIGINATING REC: EAST MIDLANDS

DATE: 15/01/97

NO. INSTALLED IN MANWEB: 4

NO. INSTALLED IN SCOTLAND:

STATUS:

DAR s to be disabled when personnel on site. Breakers to be closed remotely and with all personnel cleared from site.

REASON:

Midlands Electricity reported two failures, 6 others world-wide. Failure of mechanism could result in disruptive failure.

UPDATE:

30/12/97: Restriction removed in East Midlands electric, believed to occur during commissioning or early service life only. Restriction to remain in force in Manweb pending further discussion with manufacturer.

03/04/98: Restriction removed in Manweb.

REMEDIAL ACTION: