



1 SCOPE

This document details the application of SOP 186 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Whip & Bourne Type DV 11kV VT

ORIGINATING REC: Scottish Hydro Electric

DATE: 30/06/97

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: RESTRICTION (No equipment of this type in MANWEB)

VT's to be withdrawn and replaced DEAD.

REASON:

Electric shock received from chassis of VT as it was pushed into the service position.

UPDATE:

REMEDIAL ACTION:

Manufacturer considering improvement to tank earthing.