



1 SCOPE

This document details the application of SOP 190 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: South Wales Switchgear Type HG36
GCB

ORIGINATING REC: Midlands Electricity

DATE: 13/08/97

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: RESTRICTION

- (1) No access to compound whilst LIVE.
- (2) All Switching operations to be carried out remotely

REASON:

UPDATE:

REMEDIAL ACTION: