



1 SCOPE

This document details the application of SOP 195 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Brush 11,000V P.M.R.

ORIGINATING REC: East Midlands Electric

DATE: 31/10/97

NO. INSTALLED IN MANWEB: 0
NO. INSTALLED IN SCOTLAND

STATUS: Ban: (no equipment of this type in Manweb)

All units to be made inoperative. The units must not be allowed to operate whilst energised.

REASON:

Catastrophic failure in East Midlands Electric.

UPDATE:

07/11/97: Reassured by manufacturer that the gas leak probably only applies to type P.M.R. 3

REMEDIAL ACTION: