



## 1 SCOPE

This document details the application of SOP 200 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE :** Crompton & Parkinson Type UIDE 6.6kV Oil Switch

**ORIGINATING REC:** Northern Ireland Electric

**DATE:** 28/02/98

**NO. INSTALLED IN MANWEB:** 0

**NO. INSTALLED IN SCOTLAND:**

**STATUS:**

Ban on Live Operation until the units have been inspected and the grommets around the test access holes removed.

**REASON:**

It was found that during maintenance the rubber grommets around the test access holes were lying inside the oil tank with the possibility of jamming the mechanism.

**UPDATE:**

**REMEDIAL ACTION:**