



1 SCOPE

This document details the application of SOP 205 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Hawker Siddeley/Brush PMR3

ORIGINATING REC: SWEB

DATE: 16/06/98

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS:

Restriction (no equipment of this type in Manweb). Also see SOP 195.

REASON:

Letter from manufacturer advising against operation or work on PMR3 at the pole prior to checking pressure. Incidents have arisen where gas has been lost due to handling.

UPDATE:

REMEDIAL ACTION: