



1 SCOPE

This document details the application of SOP 217 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Metropolitan Vickers VIRHIR & S 11kV 400/600/800A

(Units modified from dependant manual operation to spring closing by GEC in 1985)

ORIGINATING REC: Midlands Electric

DATE: 19/10/97

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS:

Restriction (no equipment of this type on Manweb network)

Closing by dead operation only, no earthing via OCB.

REASON:

Failure of ocb to latch when closing.

UPDATE:

REMEDIAL ACTION:

Units to be removed from network in originating REC.