



1 SCOPE

This document details the application of SOP 221 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Hawker Siddeley Type VMH 11kV circuit breakers.

ORIGINATING REC: Eastern Electric

DATE: 23/12/98

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction (no equipment of this type in Manweb)

Operation of the EARTH switch to earth the feeder is subject to a special procedure in Eastern Electric.

REASON:

It has been observed that when the operating handle of the earth switch is moved to charge the springs, the earth switch position indicator also moves and indicates "EARTH ON" before the springs release and the switch blades move.

UPDATE:

REMEDIAL ACTION:

A modification is awaited from the manufacturer.