



1 SCOPE

This document details the application of SOP 224 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Fuller Type HD 132kV Tap Changer

ORIGINATING REC: SWALEC

DATE: 13/01/99

NO. INSTALLED IN MANWEB: 1 (Ince Local)

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction.

The above tap changer is to be operated only via automatic voltage control or by "pushbutton" control at the automatic voltage control panel.

REASON:

As a precaution pending the findings of the investigation into the incident reported in DIN 99/005

UPDATE:

REMEDIAL ACTION: