



1 SCOPE

This document details the application of SOP 225 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Reyrolle Type SPLA 275kV SF6 Circuit Breaker.

ORIGINATING REC: Scottish Hydro Electric

DATE: 25/01/99

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction (no equipment of this type on Manweb system)

The following restriction has been applied in Scottish Hydro Electric:

No routine switching operations are to be carried out with any person in the 275kV compound. This restriction also applies to generator start up until after generator synchronisation.

REASON: Catastrophic failure of SF6 CB

UPDATE:

REMEDIAL ACTION: Investigation with manufacturer is ongoing on an urgent basis.