

1. SCOPE

This document details the application of SOP 226 (Applicable to Bonar Long LV Pillars) issued by the Energy Networks Association.

2. ISSUE RECORD

This is a Reference document. The current version is held on the EN Document Library.

It is your responsibility to ensure you work to the current version.

Issue Date	Issue No.	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document
August 2024	2	Benjamin Hughes	Re-format of document. Removed reference to DIN document.

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
Benjamin Hughes Lead Engineer	Jon Ruiz De Aguirre Substations Manager	Fraser Ainslie Head of Engineering Design and Standards

4. REVIEW

This is a Reference document which has a 5 year retention period after which a reminder will be issued to review and extend retention or archive.

5. DISTRIBUTION

This document is not part of a Manual maintained by Document Control and does not have a maintained distribution list. It is published on the SP Energy Networks website.

6. CONTENTS

1. SCOPE.....	1
2. ISSUE RECORD.....	1
3. ISSUE AUTHORITY	1
4. REVIEW	1
5. DISTRIBUTION.....	1
6. CONTENTS	2
7. SOP DETAILS	2
8. SOP HEADER	3

7. SOP DETAILS

EQUIPMENT TYPE	Bonar Long LV Pillar
ORIGINATING COMPANY	East Midlands Electric
DATE	05/03/99
NUMBER INSTALLED IN ENERGY NETWORKS NORTH	
NUMBER INSTALLED IN ENERGY NETWORKS SOUTH	
REASON	
STATUS IN INITIATING COMPANY	
SPEN APPLICATION	Restriction: The following restriction applied by East Midlands Electric. No operation of the Transformer links with either the Transformer or the LV busbars live. The integrity of the links and barriers to be checked before re-energising.
ADDITIONAL INFORMATION	
UPDATE	
REMEDIAL ACTION	

8. SOP HEADER

Field Name	Field Value	Field Size
Name (SOPXXX) *	SOP226	6
The reason for the Operational Restriction *	See DIN 98/94	30
Nature of the Operational Restriction *	No live op Check links/barriers before energise	50
Comments *	No operation of the Transformer links with either the Transformer or the LV busbars live. The integrity of the links and barriers to checked before re-energising.	200
Restricted Access to Substation Flag *	N	1
SOP Impact Code * (highlight or underline the appropriate code)	0 Temporary/Impact under assessment 1 Very minor operational/network impact <u>2 Moderate operational/network impact</u> 3 Significant impact on system perf./measurable business costs 4 Inoperable without intervention 5 Inoperable – no cost effective solution/must be replaced	N/A
SOP component type * (highlight or underline the appropriate code)	01 Bushing only 02 Circuit Breaker 03 Fixed Portion only 04 Moving Portion only <u>05 Switch</u> 06 RMU 07 Transformer only 08 Tap Changer only 09 Transformer & Bushing 10 Transformer & Tap Changer	N/A
Search Criteria *	Manufacturer: Bonar Long Equipment: LV Pillar	N/A

* This denotes a Mandatory Field