



1 SCOPE

This document details the application of SOP 226 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Bonar Long LV Pillar

ORIGINATING REC: East Midlands Electric

DATE: 05/03/99

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction:

The following restriction applied by East Midlands Electric.

No operation of the Transformer links with either the Transformer or the LV busbars live.
The integrity of the links and barriers to checked before re-energising.

REASON: See DIN 98/94

UPDATE:

REMEDIAL ACTION: