



1 SCOPE

This document details the application of SOP 230 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Reyrolle 66kV small oil volume OCB.

ORIGINATING REC: Midlands Electric.

DATE: 21/04/99

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction (No equipment of this type in Manweb).

The following restriction applied by Midlands Electric:

Remote operation only, Access for essential operations only.

REASON:

Flashover within 66kV SOV OCB appears to have been caused by low oil level.

UPDATE:

REMEDIAL ACTION: