



1 SCOPE

This document details the application of SOP 231 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: ABB Type ZV2 33kV Switchgear

ORIGINATING REC: SCOTTISHPOWER

DATE: 11/05/99

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction (No equipment of this type on the Manweb system).

The following restriction shall be applied to the above switchgear:

Opening of the test prod access cover on ABB Type ZV2 switchgear is prohibited until further notice.

REASON:

An engineer received serious burns while carrying out switching operations on an ABB TypeZV2 33kV Panel switchboard at Townhill Grid substation, Dunfermline.

UPDATE:

REMEDIAL ACTION: