



1 SCOPE

This document details the application of SOP 234 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: Reyrolle Type SPL2 275kV CB

ORIGINATING REC: NGC

DATE: 25/05/99

NO. INSTALLED IN MANWEB: 0

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction (No equipment of this type on Manweb system).

The following restriction will be imposed by NGC:

Hazard area of 55m Created around all affected equipment and access to these areas being controlled during opening operations.

REASON: Failure believed to be associated with opening operation.

UPDATE:

REMEDIAL ACTION: