



1 SCOPE

This document details the application of SOP 236 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE: All 33kV Transformer cable boxes filled with G38 resin.

ORIGINATING REC: Northern Ireland Electric

DATE: 16/07/99

NO. INSTALLED IN MANWEB:

NO. INSTALLED IN SCOTLAND:

STATUS: RESTRICTION. (Not applied in MANWEB).

The following restriction imposed by Northern Ireland Electric:

Work and/or testing in the vicinity of transformer cable end boxes shall be limited to essential operations only until all sites have been evaluated.

REASON: See DIN 99/32 and 99/49.

UPDATE:

REMEDIAL ACTION: