



## 1 SCOPE

This document details the application of SOP 241 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** LUCY 11kV Type SFRMU-CF2

**ORIGINATING REC:** DEO

**DATE:** 03/08/99

**NO. INSTALLED IN MANWEB:** 0

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** No equipment of this type on Manweb system

The following restriction has been applied by the originating company:

Dead operation only, restricted access.

**REASON:** Failure of unit during switching.

Initial investigation shows evidence of verdigris and discharge.

**UPDATE:**

**REMEDIAL ACTION:**