



## 1 SCOPE

This document details the application of SOP 250 issued by the Electricity Association.

## 2 ISSUE RECORD

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

## 3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards .....



#### 4 SOP DETAILS

**TYPE:** Reyrolle C Type 11kV OCB

**ORIGINATING REC:** Midlands Electric

**DATE:** 17/03/2000

**NO. INSTALLED IN MANWEB:** 0

**NO. INSTALLED IN SCOTLAND:**

**STATUS:** Restriction (No equipment of this type remaining in Manweb)

The following restriction imposed by Midlands Electric: Springs to be charged only with the OCB in the isolated position.

**REASON:**

OCB started to slow close when springs were being recharged.

**UPDATE:**

**REMEDIAL ACTION:**