



1 SCOPE

This document details the application of SOP 258 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
October 2000	1	Esther Stewart	Initial Issue in New Format: 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
Esther Stewart	Roger Bracey	Roger Bracey Group Head, Standards



4 SOP DETAILS

TYPE : Merlin Gerin 11kV/433V 650kVA and 1250 kVA package substation

ORIGINATING REC: Northumbrian Water

DATE: 07/08/00

NO. INSTALLED IN MANWEB: None

NO. INSTALLED IN SCOTLAND:

STATUS: Restriction: **NO ACCESS WHILST SUBSTATION LIVE**
No equipment of this type in Manweb.

REASON:

Restriction imposed by Northumbrian Water following the discovery of a discharging cable termination within the package substation.

UPDATE:

REMEDIAL ACTION:

Cables and terminations to be checked and renewed as required.