



**1 SCOPE**

This document details the application of SOP 264 issued by the Electricity Association.

**2 ISSUE RECORD**

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

<b>Issue Date</b>	<b>Issue No</b>	<b>Author</b>	<b>Amendment Details</b>
August 2002	1	David Naylor	Initial Issue 2 Page Document

**3 ISSUE AUTHORITY**

<b>Author</b>	<b>Owner</b>	<b>Issue Authority</b>
David Naylor Senior Project Engineer	Alastair Ferguson Section Head Engineering Support	Eric Leavy Engineering & Transmission Operations Manager  .....



#### 4 SOP DETAILS

**TYPE :** AEI BVRP17 11kV oil circuit breaker

**ORIGINATING REC :** ScottishPower

**DATE :** 12/10/2000

**NO. INSTALLED IN MANWEB:** None of this version

**STATUS :** Restriction: **This restriction applies to units with SP17 mechanisms which have a separate spring charging handle.** Do not charge springs with the ocb in the service position until a full functional check has been carried out with the ocb isolated and withdrawn. The ocb to be spring-charged, closed, spring charged again, and then tripped, closed and tripped. The ocb may be returned to normal service if this process is completed without problems. Otherwise maintenance must be carried out on the ocb mechanism.

**REASON:** Ocb in service slow closed.

**UPDATE:**

**REMEDIAL ACTION:** Mechanism maintenance as required.