



1 SCOPE

This document details the application of SOP 267 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
August 2002	1	David Naylor	Initial Issue 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
David Naylor Senior Project Engineer	Alastair Ferguson Section Head Engineering Support	Eric Leavy Engineering & Transmission Operations Manager



4 SOP DETAILS

TYPE : Whipp and Bourne type DV Compact Form circuit breaker type C.

ORIGINATING REC : Northern Electric

DATE : 31/10/2000

NO. INSTALLED IN MANWEB: None

STATUS : Restriction: Access to the front of the switchboard limited to essential/emergency work only.

REASON: Support angle bar fixing became detached.
Mechanism linkage reset position stop holding pins dislocated.

UPDATE: Manufacturer has fitted racking shaft modification and refitted fixing using "Loctite", to enable removal of restriction.

REMEDIAL ACTION: