



1 SCOPE

This document details the application of SOP 269 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
August 2002	1	David Naylor	Initial Issue 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
David Naylor Senior Project Engineer	Alastair Ferguson Section Head Engineering Support	Eric Leavy Engineering & Transmission Operations Manager



4 SOP DETAILS

TYPE : SWS type D4X circuit breaker - Special version with vertically mounted wound primary CTs in extended air filled chamber.

ORIGINATING REC : United Utilities

DATE : 04/01/01

NO. INSTALLED IN MANWEB: None of this version.

STATUS : Restriction: Access to switchroom limited to essential activities only, unless fault level reduced. No restriction on conventional SWS D4X equipment.

REASON: Disruptive failure within CT chamber.

UPDATE:

REMEDIAL ACTION: